



Junction Boxes

Installation Instructions


56JB1SWA Series



Standard conduit entry configurations;
Bottom entry 3 x 20mm



Screw appropriate cable gland into junction box. Ensure IP66 cable gland is used and appropriately sealed to enclosure.



Technical Specifications

Cat. No.	Entry Thread 'C'	Cable Dia 'A' Max.	Cable Dia 'B' Min. - Max.	Max Across Corners	PVC Shroud Ref
CW20/16	20	8.6	8.0-13.4	24.4	MGS 04
CW20S	20	11.6	11.4-15.9	26.6	MGS 04
CW20	20	13.9	15.0-20.9	33.3	MGS 06

All Dimensions in Millimetres

Installation Kit supplied includes;

- 1 x Internal Earth Connector (Washer Style)
- 3 x Active Connectors (563G2)
- 1 x Neutral Connector (563N10)
- 1 x Earth Connector (563E10)

Ensure the earthing system is connected to the enclosure in accordance with AS3000 and the earth plate is appropriately earthed.

Products of Gerard Industries Pty Ltd

ACN 007 873 529

12 Park Terrace, Bowden, South Australia 5007

Telephone (08) 8269 0511 Facsimile (08) 8340 1724