


CLIPSAL[®]

by Schneider Electric



Full IP66 Applications

56 SERIES[™]

Use of Caps and Sealant

Installation Instructions

Ensure all the screws are covered with the appropriate caps enclosed.

Before fitting bridge, apply sealant to slots.

Conduit entry points may require sealing due to condensation.

Suitable silicone sealants:

Dow Corning 732

Dow Corning 1080

Dow Corning 739 Plastic Adhesive

Selleys Window and Glass Sealant

Ramset RC 804

Ados Neutral Cure Sealant

Schneider Electric (Australia) Pty Ltd

clipsal.com

Contact us: clipsal.com/feedback

National Customer Care Enquiries:

Tel 1300 2025 25

Fax 1300 2025 56

Schneider Electric (Australia) Pty Ltd reserves the right to change specifications, modify designs and discontinue items without incurring obligation and whilst every effort is made to ensure that descriptions, specifications and other information in this catalogue are correct, no warranty is given in respect thereof and the company shall not be liable for any error therein.

© 2011 Schneider Electric. All Rights Reserved.

Trademarks are owned by Schneider Electric Industries SAS or its affiliated companies

F1821/04

CLIPCOM 22957 July 2011