

# IMPORTANT

## Earthing

Ensure continuity of the earth is maintained throughout the installation. All metal parts must be earthed according to AS/NZS3000 wiring regulations.

## IP Rating

Torque levels for fixing of cover screws should be set between 0.8Nm - 1.2Nm

To ensure the IP66 Rating is maintained, all conduit entry points and mounting holes must be sealed.

Suitable silicone sealants include:

- Dow Corning 732, 739 and 1080
- Ramset RC804 and RBC833
- Selleys Roof and Gutter Sealant

**Notice: do not use incorrect silicone sealant. Internal plastic may fail.**

## Terminal Screws

**Notice: check terminal screws for tightness before completing install, they may have loosened during transit. Failure to check may result in equipment damage.**

© 2014 Schneider Electric. All Rights Reserved.