


www.se.com  
W9 1378086 0211 A08  
05 - 2021




Torque 1.3 N.m (12 lb-in) max




Philips N 2						Ø6				
mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>	mm	C N.m	L mm	Ø mm
1 X 6,35 2 X 2,8	0,34 ... 2,5	0,34... 2,5 + 0,34... 1,5	0,75 ... 4	0,75... 4 + 0,75... 4	1,5 ... 4	1,5... 4 + 1,5... 4	7	1.3	7	3
AWG 12=3,31 mm <sup>2</sup> AWG 14=2,08 mm <sup>2</sup>			AWG 16=1,31 mm <sup>2</sup> AWG 18=0,82 mm <sup>2</sup>			AWG 20=0,52 mm <sup>2</sup>				

- Surge suppressor
- Limiteur de surtension
- Überspannungsbegrenzer
- Limitatore di sovratensione
- Limitador de sobretención
- Limitador de sobretensão
- 浪涌抑制器


LA4 KC.



LA4 KE.



**▲ ▲ DANGER / 危险**  
**HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH**  
Disconnect all power before servicing equipment.  
**Failure to follow these instructions will result in death or serious injury.**  
电击、爆炸或弧闪的危险  
在此电力设备上进行操作时，请先断开所有电源。不遵循上述说明将导致人员伤亡。



Schneider Electric Industries SAS  
35 Rue Joseph Monier  
92506 Rueil Malmaison, France

3P AC TeSys K contactors are grade 2 according to GB 21518.  
Maximum power consumption lower than 5.0 VA.  
根据GB 21518标准,  
三极 TeSys K系列交流接触器能效等级为2级,  
产品最大吸持功率低于5.0 VA

**WARNING / 警告**

**RISK OF FIRE OR ELECTRIC SHOCK(FOR CONTACTOR WITH UL HI-FAULT SHORT CIRCUIT CURRENT RATINGS ONLY)**

The opening of the branch-circuit protective device may be an indication that a fault current has been interrupted.


To reduce the risk of fire or electric shock, current-carrying parts and the other components of the controller should be examined and replaced if damaged.

**Failure to follow these instructions can result in death, serious injury, or equipment damage.**

可能有火灾或者触电的危险 (仅限UL高故障短路电流额定值的接触器)。

支路保护设备断开, 表明故障电流已被中断。为降低火灾或触电风险, 应检查带电部件和其它控制元件。如有损坏, 需及时更换。不遵循上述说明可能导致人员伤亡或设备损坏。

For Motor Starting Use Schneider Electric Overload Relay Series LR.  
电动机启动请使用施耐德电气LR系列过载继电器。



Schneider Electric Limited  
Stafford Park 5  
Telford, TF3 3BL  
United Kingdom  
www.se.com/uk

