

3-WAY BOTTOM ENTRY

JUNCTION BOX - Ex eb I, Ex eb IIC, Ex ec IIC, Ex tc IIIC

for Hazardous Area Installations

Features and Benefits

- 3-Way Bottom Entry™ Box for use in Group I mining (low impact areas), Group II and Group III applications.
- 3-Way Bottom Entry™ Box for hazardous area lighting installations.
- Screw-on lid provides ease of installation. Lid locking with a special key prevents unauthorized tampering. Supplied complete with safety securing lid lanyard.
- Only approved CCG cable glands and terminals must be used. No exposed metal parts.
- Dust and waterproof to IP66/68, when used with CCG sealed cable glands.
- No drilling or tapping of cable entries required.
- Mounting studs provided for DIN rail if using terminal blocks.
- Internal earthing to all entries and rail provided.

Technical Data

Inserts:

3-Way Bottom Entry™ Box

Box Material: Impact corrosion and UV resistant glass reinforced polyester compound

Polycarbonate (see-through adapt-a-lids)

O ring seals: Silicone or Sarlink seals. Terminals: Wellamid or Wemidd

Brass internal earthing and rail mountings

Optional Accessories: Certified Terminals, 3-Blanking Plugs and Box Spanner (Lid Locking Key)

The installer should check that the materials are suitable for the

installation environment.

Standards and Certifications

Equipment Protection Levels: INMETRO/SANS: FINISHED: Ex e IIC T6 Gb / Ex nA IIC T6 Gc / Ex tb IIIC

T70°C Db

INMETRO/SANS: UNFINISHED: Ex e IIC Gb / Ex nA IIC Gc / Ex tb IIIC Db IECEx: FINISHED: Ex eb I Mb / Ex eb IIC T6 Gb / Ex ec T6 Gc / Ex tb IIIC T70°C Db / Ex tc IIIC T70°C Dc

IECEx: UNFINISHED: Ex eb I Mb / Ex eb IIC Gb / Ex ec Gc / Ex tb IIIC Db /

Ex tc IIIC Dc

ATEX: FINISHED: (I M2 / II 2 GD / II 3 GD Ex eb I Mb / Ex eb IIC T6 Gb / Ex ec IIC T6 Gc / Ex tb IIIC T70°C Db / Ex tc IIIC T70°C Dc ATEX: UNFINISHED: (a) I M2 / II 2 GD / II 3 GD Ex eb I Mb /Ex eb IIC

Gb / Ex ec IIC $\overline{\text{Gc}}$ / Ex tb IIIC Db/ Ex tc IIIC Dc

-60°C to +55°C (Finished) Temperature Ambient: -60°C to +110°C (Unfinished) Service Temperature:

Conformance: Standard: Certificate:

IECEx IEC 60079 Parts 0, 7, 31 and IEC 60529 IECEx MSC 20.0003X (Finished) IEC 60079 Parts 0, 7, 31 and IEC 60529 IECEx MSC 20.0004U (Unfinished) **ATEX** EN 60079 Parts 0, 7, 31 CML 14 ATEX 3036X (Finished) EN 60079 Parts 0, 7, 31 CML 14 ATEX 4038X (Finished) EN 60079 Parts 0, 7, 31 EN 60079 Parts 0, 7, 31 CML 14 ATEX 4039U (Unfinished) INMETRO (Brazil) ABNT NBR IEC 60079 Parts 0, 7, 15, 31

and IEC 60529

ABNT NBR IEC 60079 Parts 0, 7, 15, 31

and IEC 60529 SANS/IEC 60079 Parts 0, 7, 15

SANS/IEC SANS/IEC 60079 Parts 31

and SANS/IEC 60529

IP66/68 2m Protection IEC 60529 Marine ABS IEC 60529

DNV-GL IEC 60529 ClassNK IEC 60079 Part 0, 7, 15, 31

Deluge Protection DTS-01 Short Circuit/ Cont. Current IEC 60947-7-2, IEC 62444 CML 14 ATEX 3037U (Unfinished)

TÜV 15.0481X

TÜV 15.0482U (Unfinished MASC S/10-216X (Finished)

(Unfinished) MASC S/10-216U IECEx CML 15.0071U ABS 20-SG1952738-PDA DNV-GL TAE0000011

TA20268M CML 14CA370-1

CATAPULT OR/15/11677_2























Conditions for Safe Use - X

- In Group I applications, the junction box must only be used in low impact areas and where it is not exposed to oils or greases.
- Only the CCG tool supplied shall be used for opening / closing the enclosure.
- Suitably certified cable glands and/or plugs shall be used in the enclosure threaded entries
- Terminal blocks shall only be used on the applicable rail and shall allow sufficient space to make connections and to close the cover / lid.
- Only the Weidmuller terminals shown in Table 2 may be used.
- The creepage and clearance between terminal blocks and from the terminal block to any earthed / bonded metallic part shall comply with the EN60079-7 requirements for the acceptable voltage of the terminal blocks.
- The current in the junction box is limited by the size of the conductor and shall not exceed the following:

Product Code	Box Size Reference	Entry Thread 'A'	Inside Dimension 'B'	Internal Diameter 'C'	Mounting Centres 'D'	Rail Mounting Centres 'E'	Outer Height 'F'	Dim. 'I'
100201-B	1	M20 x 1.5	61.0	90.0	125.0	60.0	112.0	-
100202-B	2	M25 x 1.5	100.0	123.0	162.0	92.0	160.0	81.0


















≤ 40°C Ambient

11.90 A

15.86 A

20.33 A

28.26 A

37.68 A

≤ 55°C Ambient

8.34 A

11.12 A

14.25 A

19.81 A

26.42 A

Terminal Block

2.5mm²

4mm²

6mm²

6mm²

10mm²

3-WAY BOTTOM ENTRY™ JUNCTION BOX



Wiring and Installation instructions for 3-Way Bottom Entry™ Box without components

- · Installation must be carried out by a competent person.
- The box must not be modified in any way, as this will invalidate the certification.
- Where cables enter the box they must be secured by CCG Cable Glands appropriate to the make up of the cable.
- · Unused entry apertures must be blanked with certified CCG Blanking Plugs.
- To maintain IP 66/68 a thread seal gasket between the box and cable gland must be installed.
- · Before replacing the lid, ensure the lid gasket is in place.
- The use of a CCG Box Spanner (Lid Locking Key) is required to maintain the tamper proof integrity of the box, refer Figure 1.

Wiring and Installation instructions for 3-Way Bottom Entry™ Box with components


- · Installation must be carried out by a competent person.
- · Do not install under live current conditions.
- The box must not be modified in any way, as this will invalidate the certification.
- · All wiring must be carried out in accordance with the relevant Codes of Practice.
- The wiring insulation must not extend by more than 1.0mm from the metal face of the terminal as shown in Figure 2.
- The voltage and current value of the box must not be exceeded.
 See relevant certificate for current limitations for conditions of use / schedule of limitations
- Only those terminals shown in the terminal schedule may be incorporated in the box, refer Table 1.
- Inner cable bedding must protrude into the box by a minimum of 20mm past the cable entry point.
- Not more than one single or multiple strand lead shall be connected into either side
 of the terminals.
- Only earth conductors of equal size shall be connected with rail mounted terminals.
- All terminal screws used and unused shall be tightened.
- A parallel shaft screw driver of the correct size should be used for rail mounted terminals screws.
- Where cables enter the box they must be secured by CCG Cable Glands appropriate
 to the make up of the cable.
- Unused entry apertures must be blanked with certified CCG Blanking Plugs.
- To maintain IP66/68 a thread seal gasket between the box and cable gland must be installed.
- Before replacing the lid, ensure the lid gasket is in place.
- The use of a CCG Box Spanner (Lid Locking Key) is required to maintain the tamper proof integrity of the box, refer Figure 1.

TABLE 1

Вох Туре	Box Size	Terminal Type and Size	Max Quantity	Rail Size
3-Way BE Box	1	4mm² mini terminal	8	15
3-Way BE Box	2	2.5mm ²	12	35
3-Way BE Box	2	4mm²	10	35
3-Way BE Box	2	4mm² mini terminal	12	15
3-Way BE Box	2	6mm²	8	35
3-Way BE Box	2	10mm²	7	35
3-Way BE Box	2	16 mm²	6	35
3-Way BE Box	2	35mm²	3	35

FIGURE 1

To ensure the box apparatus is tamper proof: Screw on, tighten and lock lid in place by means of a CCG Box Spanner (Lid Locking Key).



CCG Box Spanner

Product Code	Box Size
401501	20mm
401502	25mm

TABLE 2

VOLTAGE PER TERMINAL CONFIGURATION

Terminals	Volt	Earth Terminals
AKZ 4	275V	AKE 4
WDU 2.5	550V	WPE 2.5
WDU 4	550V	WPE 4
WDU 6	550V	WPE 6
WDU 10	550V	WPE 10
WDU 16	550V	WPE 16
WDU 35	550V	WPE 35







Mini Terminals for

conductor sizes 0.5 to 4mm²

