

LEDFIRE CORE COMPLIANCE

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd

Address: U5/105a Vanessa Street

Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			
BRAND	MODEL	SKU	
Ektor	EV-LEDFIRE-CORE-B	11405	

COMPLIANCE	
2293 Report	WTF24F02028828N
Safety Report	WTF22F02023924L
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION		
IP Rating	IP44 Front Face Only	
Working Temp Range	0 to 40 °C	
Input voltage	230Vac	
Input Frequency	50 Hz	
Driver Type	Fixed output	
Product Type	EM LIGHT SPU	

EMERGENCY INFORMATION				
Emergency Mode	Non-Maintained			
Emergency Duration	90 mins			
Emergency Classification	C0:D50, C90:D50			
Replacement Battery Code	01300			

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title:	Managing Director	Date: 05/01/2022	
Signat	rure: Mayall		



SDoC Document ID: LEDFIRE-CORE_11405_AU | Generated on 5th of June 2025 04:20:26 - Page 1