

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

| BRAND | MODEL                | SKU   |
|-------|----------------------|-------|
| Ektor | EV-LED FIRE-SM-PRO-B | 01690 |

## COMPLIANCE

|             |                                                                                                        |
|-------------|--------------------------------------------------------------------------------------------------------|
| 2293 Report | WTF22F05101757N                                                                                        |
| Standards   | AS/NZS 60598.1<br>AS 60598.2.22<br>AS/NZS 61347.1<br>AS/NZS 61347.2.13<br>AS CISPR 15<br>AS/NZS 2293.3 |

## OPERATIONAL INFORMATION

|                    |                    |
|--------------------|--------------------|
| IP Rating          | IP20               |
| Working Temp Range | 0 to 40 °C         |
| Input voltage      | 230Vac             |
| Input Frequency    | 50 Hz              |
| Driver Type        | DALI DT1 Emergency |
| Product Type       | EM LIGHT NETWORK   |

## EMERGENCY INFORMATION

|                          |                |
|--------------------------|----------------|
| Emergency Mode           | Non-Maintained |
| Emergency Duration       | 90 mins        |
| Emergency Classification | C0:D80 C90:D80 |
| Replacement Battery Code | 01303          |

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** J Newell