240 V a.c. Flush Mounted Mains Power Photoelectric Smoke Alarm with 9 V d.c. **Battery Backup**



755PFM4






Scan the QR code for more information about your Clipsal smoke alarm:

- · What smoke alarms can and cannot do
- · Developing and practising a plan of escape · What to do if an alarm sounds.









Do not install in garages kitchens, bathrooms or any area with high levels of

moisture, dirt or insects. For garages: A heat alarm is more suitable as it is not affected by particulates.

Suitable





ceiling



Class 1a building

Class 1b building


Smoke


Smoke alarm

by legislation)

alarms (or as required


Lounge






● Bed


Bed




Terminal markings:


Active/Line E-Loop: Earth or Loop Neutral I-Connect: Interconnect










Max. wiring length: 150 m -





10 min





General information

- · Leave these instructions with the occupant, to be retained for the life of the alarm.
- · This smoke alarm must be installed by a licenced electrician
- · Do not remove dust cover until 24 hours after all construction has been completed. Construction dust and chemicals can

cause contamination and false alarms

· Important: Dust cover must be removed before smoke alarm will operate correctly.

For your safety

A A DANGER

RISK OF ELECTRIC SHOCK, EXPLOSION OR ARC **FLASH**

- This product must only be installed and serviced by appropriately qualified and/or licenced electrical
- This product must only be used for the purpose described in these instructions and must be installed in accordance with the wiring rules and regulations in
- Isolate the electrical supply before doing any work on this product.
- Ensure the product has been correctly installed and tested for safe operation before reconnecting the

Failure to follow these instructions will result in death or serious injury.

A CAUTION

EQUIPMENT INSTALLATION HAZARD


- Ensure active and neutral from mains power are wired to the correct terminals
- Ensure the green LED is ON when mains power is supplied.
- Ensure the red LED is not flashing quickly.
- Test each interconnected unit 1 by 1. Press and hold the Test button until second burst of 3 beeps has finished. If any unit fails to alarm, check all wiring and

Failure to follow these instructions may result in injury or equipment damage.

Operating elements

Installing/replacing the backup battery

 \Rightarrow \longrightarrow •••



- · An audible beep every 40 seconds indicates the battery needs to be replaced. It is recommended to replace the battery annually on a memorable day using the calendar reminder stickers provided
- · Recommended batteries include: Goldpeak 1604S or 1604A Energizer A522, Duracell MN 1604
- · To snooze a low battery beep for 10 hours, press the Test/Hush button for 3 seconds.

Choosing the installation location ✓

NOTICE


EQUIPMENT INSTALLATION COMPLIANCE

This smoke alarm must be installed in accordance with the National Construction Code and any local state legislation

Failure to follow these instructions may result in a non-compliant installation.

Prior to installing, ensure there are no obstructions in ceiling mounting locations, such as pipes or cables.

Installing the smoke alarm



- · This smoke alarm can only be ceiling mounted.
- Use minimum cable width 1 mm² for all wiring, including interconnect wiring where used. The sensor head cannot be installed
- without a battery · Do not remove the dust cover until you are ready to test the unit. See \Rightarrow))

Mounting the smoke alarm

Connecting the smoke alarm

⇒ 🏻 🦒 (see Single alarm)

Interconnecting smoke alarms

A CAUTION **EQUIPMENT INSTALLATION HAZARD**

- All interconnected smoke alarms must be supplied from the same circuit.
- A common Neutral must be used for the Interconnect to operate
- DO NOT connect the Interconnect wire to Active or
- Neutral.
- Maximum of 40 interconnected smoke alarms.
- Only Clipsal smoke alarms are compatible for

Failure to follow these instructions may result in injury or equipment damage.

Maximum wire length between first and last alarm is 150 m.

Operating the smoke alarm

Testing the smoke alarm

interconnection with this alarm

⇒ »)T

A CAUTION

DO NOT USE OPEN FLAME

Never use an open flame of any type to test your alarm. Failure to follow this instruction may result in injury or equipment damage.



- Test the smoke alarm once per month to ensure proper operation
- · If no alarm sounds, check the battery orientation or replace the battery (see \implies \longrightarrow \longrightarrow). If the battery is new, installed in the correct orientation and the alarm still doesn't sound, replace the smoke alarm.
- · If the smoke alarm is installed in a mobile home, test weekly and before every iournev
- · IMPORTANT: If premises are unoccupied for a more than a few days, a battery test must be undertaken upon return. If the low battery warning sounds, replace with new battery and test again.
- · Check that all interconnected smoke alarms operate during the test.

Interconnected smoke alarms

- · Test each alarm in an interconnected group.
- · For each alarm test, ensure that all interconnected alarms operate.

Silencing the smoke alarm (Hush feature)



- · When the Test/Hush button is pressed during an alarm event, the smoke alarm is not sensitive to smoke for 10 minutes. after which the alarm resumes normal operation. During this hush time, the red LED flashes once every 8 seconds.
- Wait 10 minutes before performing any additional testing to avoid any abnormal

Snoozing low battery, fault and alarm memory indications

 $\Rightarrow z^Z$ Low battery



When the backup battery gets low, the red LED flashes once every 40 seconds, together with a beep. You can snooze the low battery indication for 10 hours by pressing the Test/ Hush button for 3 seconds.

Replace the backup battery as soon as possible.

Alarm fault

When an alarm fault is detected, the red LED flashes twice every 40 seconds, together with 2 beeps. You can snooze the alarm fault indication for 10 hours by pressing the Test/Hush button for 3 seconds.

Alarm memory

In an interconnected alarm group, the red LED on the triggered alarm flashes once every 2 seconds for 72 hours after the alarm beeping has stopped, so that you can identify the unit as the alarm that was triggered. Press the Test/Hush button for 3 seconds to snooze the flashing LED for 10 hours. The snooze function for the alarm memory can be repeated as often as desired up to the 72 hour limit.

LED and sound indications

	mode			
	Normal mode / Standby mode	1 flash every 40 s	OFF	_
MODE	Local alarm	1 flash every 1 s	Continuous siren	_
	Interconnected alarm	OFF	Continuous siren	_
	Test mode	1 flash every 1 s	Siren (3 s)	
	Hush mode	1 flash every 8 s	OFF	10 min
(triggered alarm only)	Normal	1 flash every 2 s after alarm stops	OFF	Total 72 hrs
	Hushed during alarm	1 flash every 2 s after Hush started	OFF	Total 72 hrs
	Snooze	See Snooze Mode		
	Low battery mode	1 flash every 40 s	1 beep every 40 s	Until backup battery is replaced
	Fault mode	2 flashes every 40 s	2 beeps every 40 s	Until fault has been cleared
SNOOZE MODE	Low battery	1 flash every 24 s	OFF	10 hrs
	Fault	1 flash every 24 s	OFF	10 hrs
	Alarm memory	1 flash every 40 s	OFF	10 hrs

Green LED

ON	ON	_	_

Troubleshooting

	Problem	Cause and Resolution
ALERTS AND SILENCING	Alarm sounds and the red LED is	Smoke has activated the smoke alarm.
	blinking rapidly	Vacate the building immediately and call the Fire and Emergency Services. See False Alarm section.
	Alarm sounds but the red LED is OFF	Smoke has activated an interconnected alarm, located somewhere else in the building.
		Vacate the building immediately and call the Fire and Emergency Services. See <i>False alarm</i> section.
	Smoke alarm is sounding, it stops when Test/Hush is pressed	Hush or silence feature has been activated for 10 minutes providing the smoke density does not increase.
		Ensure you are safe and have put out the source of the smoke. See False alarm section.
	Red LED is flashing every 2 seconds	Alarm memory has been activated, indicating that this alarm was the triggered alarm in the group.
		LED stops flashing after 72 hours. Press Test/Hush to snooze the LED indication for 10 hours.
	When Test/Hush button is pressed for three seconds alarm	The smoke alarm horn is indicating that all electronic circuitry, horn and battery are working.
	sounds briefly	Normal test condition.
		Test regularly to ensure proper operation.
	When Test/Hush button is pressed for	The smoke alarm may not be operating correctly.
	three seconds alarm does not sounds	Check and ensure that the green LED is ON and the red LED flashes once every 40 seconds. If the problem persists contact an electrician for replacement.
	One audible beep every 40 seconds	Low battery warning. Replace the 9 V d.c. battery with new battery.

The smoke alarm may not be

operating correctly.

Mains power may be

Wiring could be wrong.

Check mains power ON. Main circuit breaker may have tripped.

disconnected.

Clean smoke alarm according to the Maintenance, Repairs and Service section. If problem persists, contact an electrician for

Two audible beeps

very 40 seconds

	replacement.
Smoke alarm body will not close on the base	9 V d.c. backup battery is not installed. Insert a new 9 V d.c. battery.
Red LED not flashing every 40 seconds	Battery may be reversed, not present or completely flat. Check and re-install or replace the battery.
Red LED flashes very quickly (3 times per second)	Neutral connection is bad or wiring is wrong. Check wiring and connection of smoke alarms with flashing red LED and rectify wiring issue
	will not close on the base Red LED not flashing every 40 seconds Red LED flashes very quickly (3 times per

False Alarm

Green LED of

In the event of a false alarm in an interconnected group, it is important to identify the triggering alarm(s). These alarms may need to be cleaned. serviced or replaced if necessary.

When alarms are sounding without any smoke present: · Identify which smoke alarm(s) are being triggered

- Look for the alarm(s) with sound and red LED
- · Unclip all identified smoke alarms. Any remaining interconnected alarms will stop alarming in 1 minute.
- · If the alarming stops before you have identified the alarms that are being triggered, look for any alarms with the red LED flashing once every 2 seconds. This flashing can be snoozed for 10 hours by pressing the Test/Hush button for 3 seconds. The snooze function can be repeated as often as desired up to the 72 hour limit.
- Clean affected smoke alarms in accordance with the Maintenance, Repairs and Service section.

· Re-install and test all the smoke alarms

for replacement.

If all of the above fails, contact a licenced electrician

Maintenance Red LED Sound Duration It is recommended that the smoke alarm is inspected monthly to ensure it is free from dirt, dust and insects. The alarm can be vacuumed or brushed with a soft brush to remove dust, dirt or kitchen grease that has

spray to a cloth and wipe around alarm/s every

Maintenance, Repairs and Service

3-6 months to mitigate insect ingress. ALWAYS TEST THE SMOKE ALARM AFTER CLEANING

accumulated. Apply a small amount of insect surface

Repairs and Service

NOTICE

- **EQUIPMENT MAINTENANCE INSTRUCTIONS** Test this smoke alarm regularly to ensure the unit is
- functional and that the battery is in good condition.
- Replace the backup battery every year.
- Replace the smoke alarm 10 years after date of
- Do not open the smoke alarm casing or repair the smoke alarm yourself. The only user-serviceable part is the replaceable backup battery. There are no other user-serviceable parts inside.

Failure to follow these instructions may result in equipment malfunction or failure.

Disposal

As the smoke alarm does not contain any radioactive material, disposal with normal rubbish is permitted in Australia and New Zealand.


Before disposal, move the battery disconnect switch to the disconnect position. This will prevent the low battery warning beep when the battery eventually discharges.

220-240 V a.c., 50 Hz

Technical data

Main Power Source

	· ·		
Secondary Power Source	9 V d.c. carbon zinc or alkaline battery		
Operating Current	≤40 mA		
Battery Life	1 year		
Sensing Type	Photoelectric. This alarm contains NO radioactive material.		
Operating Temperature	0 °C to 45 °C		
Ambient Humidity	5% to 95%		
Interconnecting	40 alarms over 150 metres maximum		
Terminal Provisions	Active, Neutral, Loop and Interconnect terminals, each accommodates 3 × 2.5 mm ²		
Horn Level	85 dB at three metres minimum		
Mounting Type	Ceiling mounted only		
Approvals	Activfire SAI Global RCM		
Complies with	AS 3786: 2014, AS/NZS 60065 and AS/NZS 60950.1		



at an authorised electronic waste collection point. Professional recycling protects people and the environment against potential negative effects.

Trademarks and certifications

Schneider Electric acknowledges that the Australian Standard Certified Product logo is a trademark of SAI Global, and that the Activfire Certified logo is a









Warranty

We warrant this product to be free from defects in materials and workmanship for a period of 5 (five) years from the date of installation

If you have technical questions, please contact the Customer Care Centre in your country.

33 Port Wakefield Road, Gepps Cross SA 5094 Customer Care Australia: 13 78 23

East Tamaki, Manukau 2013 After hours service: 0800 735 4357 (NZ only) Customer Care NZ: 0800 652 999



F2838/01

Customer care

Australia

www.schneider-electric.com.au New Zealand Schneider Electric (NZ) Ltd 38 Business Parade South, Highbrook,

e: customercare.au@schneider-electric.com



Schneider Electric (Australia) Pty Ltd

e: sales@nz.schneider-electric.com www.schneider-electric.com