
# **XUSL4E14F061N**

XUSL type 4 - Finger protection - Std sensing range - Hp = 610 mm, R=14mm





#### Main

Range of product	Preventa Safety detection		
Product or component type	Safety light curtain type 4		
Device short name	XUSL4E		
Output type	2 safety outputs OSSD solid-state PNP (integrated arc suppression)		
Product specific application	For finger protection		
Minimum object diameter for detection	14 mm		
[Sn] nominal sensing distance	16 m by cabling 03 m by cabling		
Height protected	610 mm		
Number of beams	60		
Type of start	Automatic Manual		
Control type	Selected by wiring		

#### Complementary

Detection system	Transmitter-receiver system
Response time	9 ms
Kit composition	Adjustable mounting bracket(s) 1 receiver(s) 1 transmitter(s) 1 user guide with certificate of conformity on CD-ROM
[EAA] effective aperture angle	+/- 2.5 ° at 3 m
Emission	IR LED ( $\lambda = 950 \text{ nm}$ )
[Us] rated supply voltage	24 V DC (+/- 20 %)
Supply	Power supply must meet requirements of IEC 61496-1 Power supply must meet requirements of IEC 60204-1
[le] rated operational current	2 A
Current consumption	42 mA no-load (transmitter) 83 mA no-load (receiver) 42 mA (transmitter) 900 mA with maximum load (receiver)
Output current limits	0.4 A for safety outputs OSSD
Output voltage	24 V
Output circuit type	DC
Voltage drop	<= 0.5 V
Local signalling	1 multi-colour LED (transmitter) 2 dual colour LEDs (receiver)
Electrical connection	1 male connector M12 5 pins (transmitter) 1 male connector M12 8 pins (receiver)
Function available	Test Muting through external safety module XPSLCMUT1160 LED display of operating modes and faults
Marking	CE
Material	Casing : aluminium Front panel : polycarbonate End caps : polypropylene
Housing colour	RAL 3000 : red
Fixing mode	By fixing brackets

Product weight	1.2 kg
Offer type	Standard distance


## **Environment**

directives	89/336/EEC - electromagnetic compatibility 2002/96/EC - WEEE directive 2002/95/EC - RoHS directive 98/37/EEC - machinery 89/655/EEC - work equipment			
product certifications	CE CULus TÜV			
safety level	SIL 3 conforming to IEC 61508  Type 4 conforming to IEC 61496-1  SILCL 3 conforming to IEC 62061  Category 4 conforming to EN/ISO 13849-1  PL = e conforming to EN/ISO 13849-1			
environmental characteristic	Resistance to light disturbance conforming to EN/IEC 61496-2			
service life	20 yr			
safety reliability data	PFHd = 1.75E-8 1/h conforming to IEC 61508			
ambient air temperature for operation	-2055 °C 14131 °F			
ambient air temperature for storage	-3570 °C -13158 °F			
relative humidity	095 % without condensation			
IP degree of protection	IP65 IP67			
shock resistance	10 gn for 16 ms conforming to IEC 61496-1			
vibration resistance	0.35 +/- 0.05 mm (f = 1055 Hz) conforming to IEC 61496-1			


## Offer Sustainability

Sustainable offer status	Green Premium product
RoHS (date code: YYWW)	Compliant - since 1425 - Schneider Electric declaration of conformity
REACh	Reference not containing SVHC above the threshold
Product environmental profile	Available
Product end of life instructions	Available


## **Dimensions**



## **Brackets Dimensions**




## **Mounting and Clearance**



- (1) Insert
- (2) Bracket
- (3) Washer
- (4) Spring washer
- **(5)** Nut

## **Wiring Diagrams**

#### **Transmitter Connections**




- (1) +24 Vdc
- (2) Configuration\_0
- (3) 0 Vdc
- (4) Configuration\_1
- (5) FE

Transmitter configurations and operating modes

	High range option	Low range option	Transmitter in Test state	Forbidden wiring
Pin 4 : Configuration_1	24 V	0 V	0 V	24 V
Pin 2 : Configuration_0	0 V	24 V	0 V	24 V

#### **Receiver Connections**




- (1) OSSD1
- (2) + 24 V
- (3) OSSD2
- (4) Configuration\_A
- (5) K1\_K2 Feeback/Restart
- (6) Configuration\_B
- (7) 0 Vdc
- (8) FE


#### **Receiver Configurations and Operating Modes**

#### **Automatic Start/Restart**

Without External Device Monitoring (EDM) feedback loop




With External Device Monitoring (EDM) feedback loop




## Manual Start/Restart

Without External Device Monitoring (EDM) feedback loop




(1) Restart

With External Device Monitoring (EDM) feedback loop



(1) Restart

# **Connecting to a Safety Interface**



- 1: Click on Download & Documents
- 2: Click on System user guide

To have all connection schematics concerning our safety module, select "download and document" and download the file "Safety light curtains association with safety interfaces"