# XPSMCMDI1200MT

12 inputs expansion module for safety mats with screw term





#### Main

Range of product	Preventa Safety automation
Product or component type	Safe input expansion module
Device short name	XPSMCM
Electrical connection	Screw terminal
[Us] rated supply voltage	24 V (- 2020 %) DC
Number of inputs	12 digital
Number of outputs	8 test for line control
Discrete input type	PNP
Discrete output type	PNP
Function of module	Discrete input safety mat monitoring

### Complementary

Power consumption in W	<= 3 W	
Power dissipation in W	3 W	
Integrated connection type	Backplane expansion bus	
Number of terminal blocks	6	
Connections - terminals	2-wire captive screw clamp terminals, removable terminal block 1-wire captive screw clamp terminals, removable terminal block	
Safety level	Can reach SIL 3 conforming to EN/IEC 61508 SILCL 3 conforming to IEC 62061 Can reach category 4 conforming to EN/ISO 13849-1 Can reach PL = e conforming to EN/ISO 13849-1	
Quality labels	CE	
Discrete input voltage	24 V DC	
Local signalling	1 LED green with PWR marking for power ON 1 LED green with RUN marking for RUN (status) 1 LED red with E IN marking for internal error 1 LED red with E EX marking for external error 2 LEDs orange with ADDR marking for node address 12 LEDs yellow with IN marking for input status	
Cable cross section	(0.21.5 mm² - AWG 24AWG 16) flexible cable without cable end (0.22.5 mm² - AWG 24AWG 14) flexible cable without cable end (0.251 mm² - AWG 23AWG 18) flexible cable with cable end, without bezel (0.252.5 mm² - AWG 23AWG 14) flexible cable with cable end, with bezel (0.51.5 mm² - AWG 20AWG 16) flexible cable with cable end, with double bezel (0.21 mm² - AWG 24AWG 18) solid cable without cable end (0.22.5 mm² - AWG 24AWG 14) solid cable without cable end (0.252.5 mm² - AWG 23AWG 14) flexible cable with cable end, without bezel	
Mounting support	Omega 35 mm DIN rail conforming to EN 50022	
Depth	22.5 mm	
Height	99 mm	
Width	114.5 mm	
Product weight	0.25 kg	

#### **Environment**

standards	EN/IEC 61508 EN/IEC 61800-5-1 EN/ISO 13849-1 IEC 62061	
product certifications	CULus TÜV	


	RCM
IP degree of protection	IP20 for enclosure
ambient air temperature for operation	-1055 °C
ambient air temperature for storage	-2085 °C
relative humidity	1095 %
pollution degree	2
[Uimp] rated impulse withstand voltage	4 kV conforming to EN/IEC 61800-5-1
safety reliability data	DC > 99 % MTTFd < 100 years at high PFHd = 3.24E-9 1/h
insulation	250 V AC between power supply and housing conforming to EN/IEC 61800-5-1
overvoltage category	II
electromagnetic compatibility	Electrostatic discharge immunity test - test level 6 kV, on contact conforming to EN/IEC 61000-4-2 Electrostatic discharge immunity test - test level 20 kV, on air conforming to EN/IEC 61000-4-2 Susceptibility to electromagnetic fields - test level 10 V/m, 801000 MHz conforming to EN/IEC 61000-4-3 Susceptibility to electromagnetic fields - test level 30 V/m, 1.4 GHz2 GHz conforming to EN/IEC 61000-4-3
vibration resistance	+/-0.35 mm (f = 1055 Hz) conforming to EN/IEC 61496-1
shock resistance	10 gn (duration = 16 ms) shocks : 1000 shocks on each axis EN/IEC 61496-1
service life	20 yr

# Offer Sustainability

Sustainable offer status	Green Premium product
RoHS (date code: YYWW)	Compliant - since 1450 - Schneider Electric declaration of conformity
REACh	Reference not containing SVHC above the threshold
Product environmental profile	Available
Product end of life instructions	Available

## **Dimensions**


### **Screw Terminal**




# **Mounting Safety Controller CPU with Module(s)**

**Mount BackPlane Connector on Rail** 










- 1: Connect as much Backplane Connector as module to be install.
- 2: Fix the connectors to the rail (Top first).

## Mount Safety Controller CPU with Other Module(s)








- 1: Mount controller CPU and modules on rail.
- 2: Make sure that the controller CPU or the module(s) are plugged on the BackPlane connector.

# Wiring


#### **Terminal Designation**



Terminal	Signal	Description
1	24 VDC	24 Vdc power supply
2	NODE_ADDR0	Node selection
3	NODE_ADDR1	
4	0 VDC	0 Vdc power supply
5	INPUT1	Digital input 1
6	INPUT2	Digital input 2
7	INPUT3	Digital input 3
8	INPUT4	Digital input 4
9	OUT_TEST1	Short circuit detected output
10	OUT_TEST2	
11	OUT_TEST3	
12	OUT_TEST4	
13	INPUT5	Digital input 5

14	INPUT6	Digital input 6
15	INPUT7	Digital input 7
16	INPUT8	Digital input 8
17	OUT_TEST5	Short circuit detected output
18	OUT_TEST6	
19	OUT_TEST7	
20	OUT_TEST8	
21	INPUT9	Digital input 9
22	INPUT10	Digital input 10
23	INPUT11	Digital input 11
24	INPUT12	Digital input 12

## Wiring Example



(1) Safety mat