

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



| PRODUCT INFORMATION | | |
|---------------------|--------------------|-------|
| BRAND | MODEL | SKU |
| Ektor | EV-LED FIRE-ADV-LK | 10393 |

| COMPLIANCE | |
|---------------|--|
| 2293 Report | WTF21F12148395X1N |
| Safety Report | WTF22F02023927L |
| EMC Report | 687401728801 |
| Standards | AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3 |

| OPERATIONAL INFORMATION | |
|-------------------------|----------------------------------|
| IP Rating | IP44 Front Face Only |
| Working Temp Range | 0 to 40 °C |
| Input voltage | 230Vac |
| Input Frequency | 50 Hz |
| Driver Type | Wireless (IEC62386-104) with DT1 |
| Product Type | EM LIGHT NETWORK |

| EMERGENCY INFORMATION | |
|--------------------------|-----------------|
| Emergency Mode | Non-Maintained |
| Emergency Duration | 90 mins |
| Emergency Classification | C0:D63, C90:D63 |
| Replacement Battery Code | 01302 |

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: 