

UMBRA ADVANCED WIREGUARD COMPLIANCE

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd

Address: U5/105a Vanessa Street

Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			
BRAND	MODEL	SKU	
Ektor	EV-UMBRA-ADV-WG-1200-EM-TRI	12187	

COMPLIANCE	
2293 Report	WTF21F05052579N005
Safety Report	WTF21F06054417L
EMC Report	WTF21F06054409E
Certification	GMA-510861
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION		
IP20		
0 to 40 °C		
230Vac		
50 Hz		
Fixed output		
EM BATTEN SPU		

EMERGENCY INFORMATION			
Emergency Mode	Maintained		
Emergency Duration	90 mins		
Emergency Classification	C0:D63, C90:D40		
Replacement Battery Code	01302		

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title:	Managing Director	Date: 05/01/2022	
Signatu	ure: Manall		

evolt

SDoC Document ID: UMBRA-ADVANCED-WIREGUARD_12187_AU | Generated on 5th of June 2025 04:22:21 - Page 1