

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			OPERATIONAL INFORMATION	
BRAND	MODEL	SKU	IP Rating	IP65
Ektor	EV-UMBRA-ADV-IP65-1200-EM-TRI	12037	Working Temp Range	0 to 40 °C
COMPLIANCE			Input voltage	230Vac
2293 Report	WTF21F04040297N		Input Frequency	50 Hz
Safety Report	WTF21F04040286L		Driver Type	Fixed output
EMC Report	WTF21F04040288E		Product Type	EM BATTEN SPU
Certification	SGS-210801-E		EMERGENCY INFORMATION	
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3		Emergency Mode	Maintained
			Emergency Duration	90 mins
			Emergency Classification	C0:D63, C90:D40
			Replacement Battery Code	01302

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: