


DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd

Address: U5/105a Vanessa Street
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-UMBRA-PRO-DIFF-600-EM	12234

COMPLIANCE	
2293 Report	WTF21F09103996N001
Safety Report	WTF21F09103874L
EMC Report	WTF21F09103876E
Certification	GMA-511845
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3 IEC 62386-102 IEC 62386-103

OPERATIONAL INFORMATION	
IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Driver Type	DALI DT6 LED Driver
Product Type	EM BATTEN NETWORK

EMERGENCY INFORMATION	
Emergency Mode	Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D40, C90:D25
Replacement Battery Code	01302

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: