

PEARL PROFESSIONAL IP65 - SER II COMPLIANCE

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd

Address: U5/105a Vanessa Street

Kingsgrove, NSW 2208, Australia



	PRODUCT INFORMATION			
	BRAND	MODEL	SKU	
	Ektor	EV-PEARL-PRO-IP65-EM-S	11964	

COMPLIANCE	
2293 Report	WTF22F03034546N
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3 AS/NZS 4268 IEC 62386-102 IEC 62386-103

OPERATIONAL INFORMATION		
IP Rating	IP65	
Working Temp Range	0 to 40 °C	
Input voltage	230Vac	
Input Frequency	50 Hz	
Driver Type	DALI DT1 and DT8 Dimmable	
Product Type	EM LIGHT NETWORK	

MERGENCY INFORMATION		
Emergency Mode	Maintained	
Emergency Duration	90 mins	
Emergency Classification	C0:D40, C90:D40	
Replacement Battery Code	01302	

DECLARATION OF COMPLIANCE

On the basis of the test reports specified , I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

i itie:	Managing Director	Date: 05/01/2022	
Signatu	ure: Fluikk		

evolt

SDoC Document ID: PEARL-PROFESSIONAL-IP65--SER-IL_11964_AU | Generated on 5th of June 2025 04:20:57 - Page 1