

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			OPERATIONAL INFORMATION	
BRAND	MODEL	SKU	IP Rating	IP20
Ektor	EV-RAZOR-SP-CORE-24M	15353	Working Temp Range	0 to 40 °C
COMPLIANCE			Input voltage	230Vac
2293 Report	WTF22F02023743N001		Input Frequency	50 Hz
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3		Driver Type	Fixed output
			Product Type	EM EXIT SPU
EMERGENCY INFORMATION				
	Viewing Distance 24 m			
	Emergency Mode Maintained			
	Emergency Light Source Life 72Y/07M			
	AS2293.3-2018 Projection of Light source life for LED Exit signs (appendix E) Defines the projected time until the surface luminance falls below the minimum required surface luminance for an exit sign.			
	Emergency Duration 90 mins			
	Decal Size 300 x 150 mm			
	Emergency Classification C0:D5, C90:E3.2			
	Replacement Battery Code 13972			

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: