

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

| BRAND | MODEL            | SKU   |
|-------|------------------|-------|
| Ektor | EV-QUADRO-EM-PRO | 14631 |

## COMPLIANCE

|                      |                                                                                                            |
|----------------------|------------------------------------------------------------------------------------------------------------|
| 2293 Report          | WTF21F08080345N                                                                                            |
| Safety Report        | WTF21F08080328L                                                                                            |
| EMC Report           | WTF21F08080331E                                                                                            |
| Certification        | GMA-511889                                                                                                 |
| Driver Safety Report | 211-14190298-000                                                                                           |
| Driver Certification | GMA-508278-EA                                                                                              |
| Standards            | AS/NZS 60598.1<br>AS 60598.2.22<br>AS/NZS 61347.1<br>AS/NZS 61347.2.13<br>AS/NZS CISPR 15<br>AS/NZS 2293.3 |

## OPERATIONAL INFORMATION

|                    |                           |
|--------------------|---------------------------|
| IP Rating          | IP65                      |
| Working Temp Range | 0 to 40 °C                |
| Input voltage      | 230Vac                    |
| Input Frequency    | 50 Hz                     |
| Driver Type        | DALI DT1 and DT8 Dimmable |
| Product Type       | BUNKERS                   |

## EMERGENCY INFORMATION

|                          |                 |
|--------------------------|-----------------|
| Emergency Mode           | Maintained      |
| Emergency Duration       | 90 mins         |
| Emergency Classification | C0:D50, C90:D50 |
| Replacement Battery Code | 01302           |

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** J Newell