

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-LED FIRE-ADV-B-DA-JB	10995

COMPLIANCE	
2293 Report	WTF21F12148395X1N
Safety Report	WTF22F02023927L
EMC Report	687401728801
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION	
IP Rating	IP44 Front Face Only
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Driver Type	DALI DT1 Emergency
Product Type	EM LIGHT NETWORK

EMERGENCY INFORMATION	
Emergency Mode	Non-Maintained
Emergency Duration	90 mins
Emergency Classification	C0:D63, C90:D63
Replacement Battery Code	01302

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: 