


## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
Kingsgrove, NSW 2208, Australia



## PRODUCT INFORMATION

| BRAND | MODEL                   | SKU   |
|-------|-------------------------|-------|
| Ektor | EV-LED FIRE-PRO-B-DA-JB | 11538 |

## COMPLIANCE

|               |                                                                                                        |
|---------------|--------------------------------------------------------------------------------------------------------|
| 2293 Report   | WTF22F04081280N                                                                                        |
| Safety Report | WTF22F11226497L                                                                                        |
| Standards     | AS/NZS 60598.1<br>AS 60598.2.22<br>AS/NZS 61347.1<br>AS/NZS 61347.2.13<br>AS CISPR 15<br>AS/NZS 2293.3 |

## OPERATIONAL INFORMATION

|                    |                      |
|--------------------|----------------------|
| IP Rating          | IP44 Front Face Only |
| Working Temp Range | 0 to 40 °C           |
| Input voltage      | 230Vac               |
| Input Frequency    | 50 Hz                |
| Driver Type        | DALI DT1 Emergency   |
| Product Type       | EM LIGHT NETWORK     |

## EMERGENCY INFORMATION

|                          |                 |
|--------------------------|-----------------|
| Emergency Mode           | Non-Maintained  |
| Emergency Duration       | 90 mins         |
| Emergency Classification | C0:D80, C90:D80 |
| Replacement Battery Code | 01303           |

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:**

*J Newell*