

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
 Kingsgrove, NSW 2208, Australia



### PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-MERCURY-PRO-24M-REM-IP65	11871

### COMPLIANCE

<b>2293 Report</b>	WTF22F12247502N
<b>Safety Report</b>	WTD23D05096929L
<b>Standards</b>	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

### OPERATIONAL INFORMATION

<b>IP Rating</b>	IP65
<b>Working Temp Range</b>	-40 to 40 °C
<b>Input voltage</b>	230Vac
<b>Input Frequency</b>	50 Hz
<b>Driver Type</b>	DALI DT1 Emergency
<b>Product Type</b>	EM EXIT NETWORK

### EMERGENCY INFORMATION

<b>Viewing Distance</b>	24 m
<b>Emergency Mode</b>	Maintained
<b>Emergency Duration</b>	90 mins
<b>Decal Size</b>	300 x 150 mm
<b>Emergency Classification</b>	C0:E8, C90:E8, C180:D10
<b>Replacement Battery Code</b>	01302

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:** 