

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION		
BRAND	MODEL	SKU
Ektor	EV-DUO-ADV-B-DA	12141

COMPLIANCE	
2293 Report	WTF23F04082003N
Safety Report	WTD23D01003517R1L
EMC Report	WTD23D01003516R1E
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION	
IP Rating	IP65
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Driver Type	DALI DT1 Emergency
Product Type	EM LIGHT NETWORK

EMERGENCY INFORMATION	
Emergency Mode	Non-Maintained
Emergency Duration	90 mins
Replacement Battery Code	18096

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: 