

## DECLARATION OF COMPLIANCE FOR LUMINAIRES

**Issuer:** Evolt Pty Ltd  
**Address:** U5/105a Vanessa Street  
 Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION			OPERATIONAL INFORMATION	
BRAND	MODEL	SKU	IP Rating	IP20
Ektor	EV-MERCURY-PRO-24M-B-LK	12564	Working Temp Range	0 to 40 °C
COMPLIANCE			Input voltage	230Vac
2293 Report	WTF23F06142457N001		Input Frequency	50 Hz
Safety Report	WTD23D05096929L		Driver Type	Wireless (IEC62386-104) with DT1
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3		Product Type	EM EXIT NETWORK
EMERGENCY INFORMATION				
			Viewing Distance	24 m
			Emergency Mode	Maintained
			Emergency Duration	90 mins
			Decal Size	300 x 150 mm
			Replacement Battery Code	01300

## DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

**Title:** Managing Director **Date:** 05/01/2022

**Signature:**