

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-MERCURY-PRO-24M-B-DA	12562

COMPLIANCE

2293 Report	WTF23F06142457N001
Safety Report	WTD23D05096929L
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 61347.1 AS/NZS 61347.2.13 AS CISPR 15 AS/NZS 2293.3

OPERATIONAL INFORMATION

IP Rating	IP20
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Driver Type	DALI DT1 Emergency
Product Type	EM EXIT NETWORK

EMERGENCY INFORMATION

Viewing Distance	24 m
Emergency Mode	Maintained
Emergency Duration	90 mins
Decal Size	300 x 150 mm
Replacement Battery Code	13845

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature: *J Newell*