

DECLARATION OF COMPLIANCE FOR LUMINAIRES

Issuer: Evolt Pty Ltd
Address: U5/105a Vanessa Street
Kingsgrove, NSW 2208, Australia



PRODUCT INFORMATION

BRAND	MODEL	SKU
Ektor	EV-BOXIT-IP65-40M-PRO-DA	13105

COMPLIANCE

2293 Report	WTF24F07169542X1N
Safety Report	WTF24F10241925L
Standards	AS/NZS 60598.1 AS 60598.2.22 AS/NZS 2293.3 AS CISPR 15

OPERATIONAL INFORMATION

IP Rating	IP65
Working Temp Range	0 to 40 °C
Input voltage	230Vac
Input Frequency	50 Hz
Driver Type	DALI DT1 Emergency
Product Type	EM EXIT NETWORK

EMERGENCY INFORMATION

Viewing Distance	40 m
Emergency Mode	Maintained
Emergency Duration	90 mins
Replacement Battery Code	1303

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the luminaire described in this document complies with the requirements of electrical safety and the use of the RCM mark.

Title: Managing Director **Date:** 05/01/2022

Signature:

J Newell